

## Product Certification Schedule

Schedule No: 189/001/061  
Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU  
Factory: CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU  
Specification: BS EN 50525-3-41:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke  
Type of Cable: Heat resistant cables (90°C)  
Clause 4.1 - Cables for fixed wiring - H07Z-U and H07Z-R  
Table B.1 - Cables with rigid conductor (450/750 V)  
HAR Document: Not applicable  
HAR Specification: Not applicable  
Range of Approval: 1.5sqmm to 400sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Non HAR colours; yellow, green and combinations of other colours. Insulation - EI5.  
Origin Thread: Not applicable  
Origin Mark: DRAKA UK (B)

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004

## Product Certification Schedule

Schedule No. 189/001/062  
 Test Report No. F4TTA130/F7TTL130  
 Prev. Schedule No. 189/001/043  
 Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU  
 Factory: CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU  
 Specification BS EN 50525-3-41:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 3-41: Cables with special fire performance - Single core non-sheathed cables with halogen-free crosslinked insulation, and low emission of smoke  
 Type of Cable Heat resistant cables (90°C)  
 Clause 4.1 - Cables for fixed wiring - H07Z-U and H07Z-R  
 Table B.1 - Cables with rigid conductor (450/750 V)  
 HAR Document EN 50525-3-41:2011  
 HAR Specification Solid conductor: H07Z-U; Stranded conductor: H07Z-R  
 Range of Approval 1.5sqmm to 630sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Insulation - EI5.  
 Origin Thread Not applicable  
 Origin Mark DRAKA UK (B)

### PERMISSIBLE MARKS



**BASEC** ◁ HAR ▷

BLACK - 1cm  
 RED - 1cm  
 YELLOW - 3cm  
 THREAD

Note: The black - red - yellow thread has been registered in this country as an identification thread in the BSI "Register of colours of manufacturers' threads for electric cables and cords" for Verband Deutscher Elektrotechniker (VDE) e.V., Frankfurt, Germany. VDE has authorized BASEC to use this thread.

Please refer the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

This certificate is issued according to the rules of the HAR agreement. The certification Scheme meets the criteria for type 5 Scheme laid down in the ISO/IEC 17067:2013 (Type Testing, Factory Inspection with assurance of conformity by continuous sample testing, production surveillance and market surveillance). The certificate issued by any Certification Body adhering to the HAR Agreement has the same worth and validity in all the other Certification Bodies' countries. Compliance with the requirements of the above listed Harmonised Standards carries a presumption of conformity with the essential safety requirements of Directive 2014/35/EC (Low Voltage Directive).

Signed for and on behalf of the British Approvals Service for Cables

Date \_\_\_\_\_

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required

02/08/2017

