

Product Certification Schedule

Schedule No: 189/001/067

Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Part 1 : Multicore cables

Type of Cable: Table 2 - Dimensions of 2-core, 3-core and 4-core cables

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 4sqmm nominal cross-sectional area of conductors inclusive. 2-core to 4-core inclusive. ENHANCED 120. Additionally tested to BS 6387:2013 Categories C, W & Z. Sheath - LTS3. Insulation - EI2.

Origin Thread: Not applicable

Origin Mark: DRAKA UK (B) FT120

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004