

## Product Certification Schedule

Schedule No: 189/001/071

Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Specification: BS 7846:2015 Electric Cables - Thermosetting insulated, armoured, fire-resistant cables of rated voltage 600/1 000 V for fixed insulations, having low emission of smoke and corrosive gases when affected by fire - Specification.

Type of Cable: Table 4, 5, 6 & 7  
Two core, three core, four core and five core 600/1000 V cables with copper conductors

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 4sqmm to 70sqmm nominal cross-sectional area of conductors inclusive.  
Two core to three core inclusive.  
4sqmm to 50sqmm nominal cross-sectional area of conductors inclusive.  
Four core.  
4sqmm to 35sqmm nominal cross-sectional area of conductors inclusive.  
Five core.  
Resistance to fire - Category F120. Sheath - LTS1. Insulation - GP8.  
This approval is based on the use of 1.25mm armour wire for the following cables: Table 4 two core 4, 6 & 10sqmm, Table 5 three core 4 & 6sqmm, Table 6 four core 4sqmm and Table 7 five core 4sqmm.

Origin Thread: Not applicable

Origin Mark: DRAKA UK (B) FIRETUF POWER PLUS or DRAKA UK (B) FTP120

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Signed for and on behalf of the British Approvals Service for Cables

Expiry Date: 11/08/2020

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004