

Product Certification Schedule

Schedule No: 189/001/074
Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Factory: CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Specification: BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2 Electric cables - Thermosetting insulated, armoured cables for voltages of 600/1000V and 1900/3300V for fixed installations, having low emission of smoke and corrosive gases when affected by fire - Specification
Type of Cable: Tables 5, 6, 7 & 8
Two-core, three-core, four-core and five-core 600/1000V cables with copper conductors
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Five-core. Sheath - LTS1. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: DRAKA UK (B)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD


Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004