

Product Certification Schedule

Schedule No. 189/002/035
Test Report No. D2RTA063
Prev. Schedule No. 189/002/025
Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU
Factory: HARRIET STREET, TRECYNON, ABERDARE, SOUTH WALES, CF44 0TD
Specification BS EN 50525-2-31:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 2-31: Cables for general applications - Single core non-sheathed cables with thermoplastic PVC insulation
Type of Cable Clause 4.1 - Cables for fixed wiring - H07V-U and H07V-R
Table B.1 - Cables with rigid conductor (450/750 V)
HAR Document Not applicable
HAR Specification Solid conductor: H07V-U; Stranded conductor: H07V-R
Range of Approval 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1.5sqmm to 25sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Colours: black, blue, brown, grey, orange, pink, red, turquoise, violet, white and combination green/yellow. Insulation - T11.
Origin Thread Not applicable
Origin Mark DRAKA UK (A)

PERMISSIBLE MARKS



BASEC ◁ HAR ▷

BLACK - 1cm
RED - 1cm
YELLOW - 3cm
THREAD

Note: The black - red - yellow thread has been registered in this country as an identification thread in the BSI "Register of colours of manufacturers' threads for electric cables and cords" for Verband Deutscher Elektrotechniker (VDE) e.V., Frankfurt, Germany. VDE has authorized BASEC to use this thread.

Please refer the BASEC Product Certification Requirements


Expiry Date: 11/08/2020

This certificate is issued according to the rules of the HAR agreement. The certification Scheme meets the criteria for type 5 Scheme laid down in the ISO/IEC 17067:2013 (Type Testing, Factory Inspection with assurance of conformity by continuous sample testing, production surveillance and market surveillance). The certificate issued by any Certification Body adhering to the HAR Agreement has the same worth and validity in all the other Certification Bodies' countries. Compliance with the requirements of the above listed Harmonised Standards carries a presumption of conformity with the essential safety requirements of Directive 2014/35/EC (Low Voltage Directive).

Signed for and on behalf of the British Approvals Service for Cables

Date _____

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.
02/08/2017



Product Certification Schedule

Schedule No: 189/002/036

Licensee: DRAKA UK LTD, CHICKENHALL LANE, EASTLEIGH, HAMPSHIRE, SO50 6YU

Factory: HARRIET STREET, TRECYNON, ABERDARE, SOUTH WALES, CF44 0TD

Specification: BS EN 50525-2-31:2011 Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (Uo/U) - Part 2-31: Cables for general applications - Single core non-sheathed cables with thermoplastic PVC insulation

Type of Cable: Clause 4.1 - Cables for fixing wiring - H07V-U and H07V-R
Table B.1 - Cables with rigid conductor (450/750 V)

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.5sqmm to 10sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 1 conductor. 1.5sqmm to 25sqmm nominal cross-sectional area of conductors inclusive. Single-core. Class 2 conductor. Solid and stranded conductor. Colours: green, yellow and combinations of other colours. Insulation - T11.

Origin Thread: Not applicable

Origin Mark: DRAKA UK (A)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 11/08/2020

Signed for and on behalf of the British Approvals Service for Cables

Date 02/08/2017

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004