

## Certificate of Product Approval

Licensee:  
**Draka UK Ltd**

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:  
Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:  
BS 6724:2016 Incorporating Corrigenda Nos. 1 and 2

Description:  
Thermosetting insulated, armoured cables with rated voltages of 600/1000V with Low Smoke, Halogen Free sheathing

Details:  
N/A

Materials:  
Insulation GP 8, Sheath LTS 1

Brand Name:  
N/A

Origin Mark:  
DRAKA UK (B)

### Permissible Approval Marks:

**BASEC**



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 17/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**11/08/2023**

Type(s) and Range(s) of Approval

Table / Clause	Code Designation	Conductor Class	Range of Cores	Min Nominal Size -sqmm	Max Nominal Size - sqmm
5	6942B	Class 2	2	1.5	70
6	6943B	Class 2	3	1.5	70
7	6944B	Class 2	4	1.5	70
8	6945B	Class 2	5	1.5	10
9	6947B	Class 2	7	1.5	4
9	6940/12B	Class 2	12	1.5	4
9	6940/19B	Class 2	19	1.5	4
9	6940/27B	Class 2	27	1.5	4
9	6940/37B	Class 2	37	1.5	4

Signed for and on behalf of the British Approvals Service for Cables

*Tony Lioveri*

Date: 17/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:  
**11/08/2023**