



**Registration No.** 422

**Title** FT120 Circuit Integrity Alarm Cable (formerly known as Firetufplus Enhanced and Firetuf OHLS Plus cables)

**Status** Authorised For Use

**Date Authorised for Use** 23 Aug 2010

**Primary Use** Zero Halogen, Low Smoke Cables to maintain circuit integrity when exposed to fire, meeting the enhanced category of BS 5839-1:2002 +A2:2008

**Additional Info/KeyWords** Manufacturer: Draka Ltd, PO Box 6500, Alfreton Road, Derby, DE21 4ZH. Tel: 01332 345431. FT120 cables comply with LU Standard 1-085 A2 'Fire Safety Performance of Materials' and can be used in below ground locations without restriction.

**Classification Hierarchy** Premises

**Manufactured By** Draka Limited

**Supersedes ProductID** N/A

**Superseded By ProductID** N/A

**Requirements**

ReqID	Requirement	Status	Trial
No records to display.			

**Conditions**

Description	Linked To ReqID
No records to display.	

**Evidence**

EvidenceText	EvidenceType	FileName	Linked To ReqID
LUL Product Assessment	Consultation	SST 1054.pdf	
Product Guide	User Guide	FT120.pdf	
Installation Guide	User Guide	Firetuf OHLS - Firetuf Plus Enhanced r1.pdf	
Draka Letter on the Change of Product Names	Other	Draka Letter - Firetuf Alarm Cables.pdf	

Refer to Web site [www.lu-apr.co.uk](http://www.lu-apr.co.uk) to check current status, download attachments and for details of other products.

MAYOR OF LONDON