

Certificate of Product Approval

Certificate Number: 1134j

Issue: 03

DRAKA UK LIMITED

Chickenhall Lane
Bishopstoke
Eastleigh
Hants
SO50 6YU
United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
FT30 SAFFIRE
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 7629-1:2015 (STANDARD 60)
BS 6387:2013 (C,W,Z)
EN 50200:2015 (Class PH60)
EN 50200:2015 Annex E (30 mins)
BS 5839-1:2013 (Clause 26.2d Standard)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward
Certification Scheme Manager

09 August 2016
Date of Issue

15 July 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 1134j DRAKA UK LIMITED

Issue: 03

Product name						LPCB Ref. No.
FT30 SAFFIRE						1134j/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 7696-1	BS 6387	EN 50200	EN 50200 (Annex E)	BS 5839-1 Clause 26.2
1.5	2, 3 & 4 ⁽¹⁾	Standard 60 ⁽³⁾	C,W,Z	PH60	30min ⁽⁴⁾	Standard ⁽⁵⁾
2.5	2, 3 & 4 ⁽¹⁾	Standard 60 ⁽³⁾	C,W,Z	PH60	30min ⁽⁴⁾	Standard ⁽⁵⁾
4.0	2, 3 & 4 ⁽²⁾	Standard 60 ⁽³⁾	C,W,Z	PH60	30min ⁽⁴⁾	Standard ⁽⁵⁾

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. In meeting the requirements of BS 7629-1:2015, the FT30 SAFFIRE cables listed met the requirements for smoke density of EN 61034-2:2005+A1:2013, and achieved less than 0.5% HCl for the insulation, binder tape, and outer covering when tested in accordance with EN 60754-1:2014 and in addition also met the fire resistance requirements of BS 6387:2013 Categories CWZ.
4. The duration of 30min when tested in accordance with EN 50200:2015 Annex E is achieved by 15min for the fire and mechanical shock phase and a further 15min for the fire, mechanical shock and water phase.
5. The FT30 SAFFIRE cables listed conform to BS 7629-1:2015, met Class PH60 when tested in accordance with EN 50200:2015 and met the 30min duration when tested in accordance with EN 50200:2015 Annex E and hence met the requirements for a standard fire resistant cable as described in Clause 26.2 of BS 5839-1:2013.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward

Certification Scheme Manager

09 August 2016

Date of Issue

15 July 2013

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre