

Certificate of Product Approval

Licensee:

Draka UK Ltd

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Factory:

Chickenhall Lane, Eastleigh, SO50 6YU, Hampshire, United Kingdom

Standard:

BS 7846:2015

Description:

Armoured fire resistant power cables

Details:

Resistance to fire - Category F120. This approval is based on the use of 1.25mm armour wire for the following cables: Table 4, 2, 4, 6 & 10sqmm, Table 5, three-core, 4 & 6 sqmm and Table 6, four-core, 4sqmm, Table 7, five-core, 4sqmm.

Materials:

Insulation GP 8, Sheath LTS 1

Brand Name:

FTP120, FIRETUF POWER PLUS

Origin Mark:

DRAKA UK (B)

Permissible Approval Marks:

BASEC



BASEC name

BASEC roundel

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 17/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 1 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023



Type(s) and Range(s) of Approval

| Table / Clause | Code Designation | Conductor Class | Range of Cores | Min Nominal Size -sqmm | Max Nominal Size - sqmm |
|----------------|------------------|-----------------|----------------|------------------------|-------------------------|
| 4 | N/A | Class 2 | 2 | 4 | 70 |
| 5 | N/A | Class 2 | 3 | 4 | 70 |
| 6 | N/A | Class 2 | 4 | 4 | 50 |
| 7 | N/A | Class 2 | 5 | 4 | 35 |

Signed for and on behalf of the British Approvals Service for Cables

Tony Lioveri

Date: 17/11/2020

Date of original issue: 06/10/2012

Check BASEC website to verify validity.

Page 2 of 2

BASEC, Presley House, Presley Way, Milton Keynes, MK8 0ES,

Registered in England No. 1150237, Tel: +44(0)1908267300

Email: mail@basec.org.uk, Web: www.basec.org.uk



Expiry date:
11/08/2023