

Certificate of Product Approval

Certificate Number: 1134h

Issue: 03

DRAKA UK LIMITED

Chickenhall Lane
Bishopstoke
Eastleigh
Hants
SO50 6YU
United Kingdom



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
FT SIFER 950s
See Certificate Appendix for details

Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)
EN 50267-2-1:1999
IEC 60331-21:1999

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

David Hoare
Certification Scheme Manager

16 September 2014
Date of Issue

15 May 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 1134h DRAKA UK LIMITED

Issue: 03

Product name				LPCB Ref. No.
FT SIFER 950s				1134h/01
Nominal csa of conductor (mm ²)	Core Construction	BS 6387	EN 50267-2-1 (outer covering)	IEC 60331-21
1.0	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
1.5	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
2.5	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
4.0	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
6.0	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
10	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
16	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
25	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
35	One ⁽¹⁾	CWZ ^(2,3)	<0.5% HCl	Complies ⁽⁵⁾
50	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾
70	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾
95	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾
120	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare
Certification Scheme Manager

16 September 2014
Date of Issue

15 May 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 1134h DRAKA UK LIMITED

Issue: 03

Product name				LPCB Ref. No.
FT SIFER 950s				1134h/01
Nominal csa of conductor (mm ²)	Core Construction	BS 6387	EN 50267-2-1 (outer covering)	IEC 60331-21
150	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾
185	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾
240	One ⁽¹⁾	C ^(2,4)	<0.5% HCl	Complies ⁽⁵⁾
300	One ⁽¹⁾	-	<0.5% HCl	Complies ⁽⁵⁾
400	One ⁽¹⁾	-	<0.5% HCl	Complies ⁽⁵⁾
500	One ⁽¹⁾	-	<0.5% HCl	Complies ⁽⁵⁾
630	One ⁽¹⁾	-	<0.5% HCl	Complies ⁽⁵⁾
800	One ⁽¹⁾	-	<0.5% HCl	Complies ⁽⁵⁾
1000	One ⁽¹⁾	-	<0.5% HCl	Complies ⁽⁵⁾

Uo/U 600/1000 V

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare
Certification Scheme Manager

16 September 2014
Date of Issue

15 May 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 1134h DRAKA UK LIMITED

Issue: 03

Notes:

1. Stranded conductor only.
2. Where a single cable is fitted in a conduit, only phase to earth voltage was applied.
3. To satisfy the requirement of BS 6387, testing for C, W and Z categories was conducted using a 20mm stainless steel conduit as the other metallic element.
4. To satisfy the requirement of BS 6387, testing for C category was conducted using a 38mm stainless steel conduit as the other metallic element.
5. The FT SIFER 950s cables met the requirements of IEC 60331-21: 1999 when tested at a temperature of 950°C for a duration of 90mins + 15mins cool down, at voltage rating of 600V.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

David Hoare
Certification Scheme Manager

16 September 2014
Date of Issue

15 May 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

The logo for BRE Global, consisting of the lowercase letters 'bre' in a bold, sans-serif font.